

# Addendum

## Instructions for Converting Honeywell Valve Part No. VR8205S 2288 to LP/Propane Gas.

1. Turn off gas supply at the appliance service valve.
2. When converting this valve, use conversion kit part number 624642 ONLY.
3. Remove the pressure regulator adjustment screw located underneath the cap screw. For condensing furnaces, the Pressure Regulator Adjustment is located underneath the brass fitting (see Figure 1).
4. Remove the existing spring.
5. Insert the replacement spring.
6. Reinstall the plastic pressure regulator adjustment screw.
7. Check and adjust the regulator setting using a manometer.
8. Continue conversion per manufacturers instructions.




Figure 1



708292

7082920

Specifications and illustrations subject to change without notice and without incurring obligations. Printed in U.S.A. (08/03)